

Net Zero Shell House

W

BACKGROUND & CONCEPT

To explore innovative solutions for reducing carbon emissions at the University of Washington, we will develop a conceptual net-zero design for the ASUW Shell House. This design will envision how the building could achieve net-zero performance and serve as a sustainable, functional event space for UW students, faculty, and visitors to use and appreciate.

- Background**
- P2S is working on the mechanical design for the renovation of the historic UW Shell House to transform it into a event space.
  - The project’s goal was to provide a high performance building, but a net zero building was not within the budget.
  - As such, P2S is working with the ME Department to explore innovative strategies to reach net-zero.



**Significance**

As the consequences of climate change begin to take effect, it is clear that we need to reduce our carbon footprint. The built environment is responsible for ~39% of global carbon emissions, making reducing building emissions critical to our survival.

- Critical Requirements**
- Achieve Net-Zero emissions: energy consumed on-site balanced by renewable energy generated, resulting in zero net carbon emissions
  - An HVAC system that meets code, ensuring occupant comfort
  - An energy efficient HVAC system


We explored 5 systems:

|                              | Air-Water             |             | Water-Water                         |             | Air-Air              |
|------------------------------|-----------------------|-------------|-------------------------------------|-------------|----------------------|
| Central Equipment            | Heat Pump             |             | Heat Pump                           |             | VRF or VRV           |
| Source/Sink                  | Ambient Air           |             | Ground Well, Ground Loop, Lake Loop |             | Ambient Air          |
| Distribution to Building     | 4 Pipe                |             | 4 Pipe                              |             | Refrigerant Circuits |
| Inside Building Distribution | Radiant Floor w/ DOAS | AHU w/ DOAS | Radiant Floor w/ DOAS               | AHU w/ DOAS | DX system w/ DOAS    |



- Selection criteria:**
- Energy Efficiency – will impact operational cost and contribute to emissions
  - Project lifetime emissions
  - Life expectancy/maintenance – will significantly impact both cost and carbon emissions
  - Historical preservation – system integration and mechanical space requirement to minimize impact
  - Occupant comfort – how well the system is able to ventilate and condition the space as well as acoustics
  - Cost – can be prohibitive and is the driving force in all projects

SYSTEM SELECTION

- Energy Modeling: eQUEST**
- Building geometry
- Building footprint
  - Building construction (U values)
  - Fenestration (doors and glazing)



- HVAC inputs
- System definition
  - Zoning temperatures and airflows
  - Equipment type, capacity, and efficiency (CHW, HW, DHW)
  - Building controls and schedule



- Water-Water w/ Radiant Floors and DOAS**
- Minimal refrigerants, reduces GWP
  - Supports electrification
  - Low Energy Use (14.70 kBtu/ft²·yr)
  - Lower fan energy
  - Longer life expectancy
  - Minimal maintenance
  - Minimal visual/audio impact


- Load and ventilation calculations: Carrier Block Load**
- Ventilation CFM based on 2021 Seattle Mechanical Code Table 403.4.1.1
  - Area takeoffs for walls, windows, flooring, roofing, and doors
  - 2021 Seattle Energy code gave loads for lighting, infiltration, shading coefficients and misc.
  - U-factors from 2021 SEC baseline values

**Output Summary**

| Loads (BTU/hr)     | Cooling  |        | Heating  |
|--------------------|----------|--------|----------|
|                    | Sensible | Latent | Sensible |
| Zone 1 Total       | 27,353   | 2,050  | 33,475   |
| Zone 2 Total       | 259,089  | 82,000 | 114,401  |
| Zone 3 Total       | 29,862   | 10,701 | 13,301   |
| Total Zone Loads   | 301,428  | 94,751 | 161,177  |
| Total System Loads | 354,650  | 86,461 | 362,341  |
| Total Coil Loads   | 354,650  | 86,529 | 362,341  |

FINAL DESIGN

- HVAC Equipment**
- Water side
- Heat source/rejection: closed lake loop  
Source heating & cooling load from lake
  - Water to water heat pump  
Exchange heat between lake and indoor water loop serving radiant floors and fan coils.
  - Indoor distribution system: radiant floor  
Distribute heating & cooling to occupants
- Air side
- Energy Recovery Ventilator, ERV  
Recovers heat and moisture from exhaust air, provide required fresh outdoor air to meet 2021 Seattle Mechanical Code.
  - Air handling unit: fan coils and diffusers  
Fan coils provide remaining heat and cooling loads and diffusers distribute air-side conditioning.



- Photovoltaic (PV) Panel Array**
- A 2,906 sf rooftop PV array will generate 57,431 kWh per year to completely power and operate the building.
- \*Calculations performed using the NREL’s PVWatts Calculator.

|                      | Solar PV Specs    |
|----------------------|-------------------|
| DC System Size (kW)  | 54                |
| Module Type          | Premium           |
| Array Type           | Fixed (open rack) |
| System Losses (%)    | 14.08             |
| Tilt (°)             | 20                |
| Azimuth (°)          | 180               |
| AC Energy (kWh/year) | 57,431            |

Net Zero Measures: Lake Sourcing and PV Array



- Sourcing the heating and cooling loads from the lake allows us to save on energy (costs) and reduce carbon emissions
- A rooftop PV array will generate an equivalent load to the building’s operational demand. On-site solar energy sold back to the grid to offset carbon emissions, enabling the project to achieve net-zero status.

A special thanks to Peter Sloane, Mike Thomson, and Scott Rushing for your support and mentorship

**Mechanical Engineering Capstone Exposition**  
May 29<sup>th</sup> 2024, Husky Union Building, University of Washington, Seattle